

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 557, 558, 574

Dated: 20/03/2025

It is certified that an inspection team headed by Sh. Rajeev Kumar @ Lab. staff

(Name of Officers with designation) from Chemist, D.W.T.L. PHED Hisar

inspected the Dlg Vijay Memorial School, 8 km Stone Kaimri

(Name & Address of the school) on 18/03/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 557, 558, 574 dated 18/3/25 & 20/3/25

of D.W. Water Testing Lab. (PHED Lab) certified that

the Dlg Vijay Memorial School, Hisar (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6 months

PHED
20/03/2025

Signature with Seal: Chemist-cum-Quality & Technical Manager

Name

..... District Water Testing Laboratory

Designation

..... PHED, HISAR

Name & Address of the Office / Department :

To

Dlg Vijay Memorial School

8 km Stone Kaimri Road, Hisar

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

67 | Page

Payal Vishnoi

Principal

Digvijay Memorial School
Kaimri Road, HISAR

Kali
Manager

Dig Vijay Memorial School
HISAR

Memo No:- 557

Date:- 19/03/2025

Subject: Physical / Chemical Examination Report of Water Sample

HC 12/18

Sample ID/Classification : HSR/13147/3/2025 / Private		Sample Details	Date & Time
Sender : DIG VIJAY MEMORIAL SCHOOL		Collected By	DHARAMVEER
Location : , 8KM STOME KAIMRI ROAD		Collection Date	17/03/2025 at 13:45
Sample Description : Drinking Water		Received at lab	18/03/2025 at 14:09
Latitude / Longitude : 75.722601 / 29.086139		Analysis Start Date	18/03/2025
		Analysis End Date	19/03/2025
		Sample Quantity	2 Ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	63	500 mg/ltr.	2000 mg/ltr.	APHA 24th Edition -2540 C
2	Total Hardness as CaCO ₃	42.4	200 mg/ltr.	600 mg/ltr.	APHA 24th Edition -2340 C
3	Calcium as Ca	11.38	75 mg/ltr.	200 mg/ltr.	APHA 24th Edition-3500-Ca B
4	Magnesium as Mg	3.40	30 mg/ltr.	100 mg/ltr.	APHA 24th Edition -3500 Mg B
5	Total Alkalinity	44.8	200 mg/ltr.	600 mg/ltr.	APHA 24th Edition -2320 B
6	Chloride as Cl	28.36	250 mg/ltr.	1000 mg/ltr.	APHA 24th Edition -4500 Cl-B
7	Sulphate as SO ₄	12	200 mg/ltr.	400 mg/ltr.	USEPA / APHA 24th -4500 SO ₄ -E
8	Fluoride as F	0.0461	1.0 mg/ltr.	1.5 mg/ltr.	APHA 24th Edition-4500F C/
9	Iron as Fe	0.01	1.0 mg/ltr.	1.0 mg/ltr.	USEPA
10	Nitrate as NO ₃	0.4	45 mg/ltr.	45 mg/ltr.	APHA 24th Edition -4500 NO ₃ D
11	pH @ 25°C	6.65	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :

RAJEEV KUMAR, CHEMIST
DISTRICT WATER TESTING LABORATORY HISAR
email:-chemist.hisar@phedharyana.gov.in

Principal
Digvijay Memorial School
Kaimri Road, HISAR

Manager
Dig Vijay Memorial School
HISAR

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, HISAR

Website :- <https://phedharyana.gov.in/>

Memo No:- 558

Date:- 19/03/2025

Subject : Physical / Chemical Examination Report of Water Sample

HC-1219

Sample ID/Classification : HSR/13175/3/2025 / Private	Sample Details	Date & Time
Sender : DIG VIJAY MEMORIAL SCHOOL / WATER SUPPLY	Collected By	DHARAMVEER
Location : 8KM STONE KAIMRI ROAD HISAR	Collection Date	18/03/2025 at 12:11
Sample Description : Drinking Water	Received at lab	18/03/2025 at 14:10
Latitude / Longitude : 75.722601 / 29.086139	Analysis Start Date	18/03/2025
	Analysis End Date	19/03/2025
	Sample Quantity	2 Ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	400	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
2	Total Hardness as CaCO ₃	326	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
3	Calcium as Ca	64.92	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
4	Magnesium as Mg	39.85	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
5	Total Alkalinity	122.8	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
6	Chloride as Cl	212.70	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
7	Sulphate as SO ₄	70	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO ₄ -E
8	Fluoride as F	0.232	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C/
9	Iron as Fe	0.06	1.0 mg/lit.	1.0 mg/lit.	USEPA
10	Nitrate as NO ₃	1.2	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D
11	pH @ 25°C	7.38	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.

Sample analyzed by :

RAJEEV KUMAR, CHEMIST
DISTRICT WATER TESTING LABORATORY, HISAR
email:-chemist.hisar@phedharyana.gov.in



Principal
Digvijay Memorial School
Kaimri Road, HISAR

Manager
Dig Vijay Memorial School
KAIMRI ROAD



PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, HISAR

Website :- <https://phedharyana.gov.in/>

Subject : **Bacteriological Examination Report of Water Samples**

Circle Hisar Circle

Division Hisar PHED No. 1

Sub Division Hisar PHED No. 4

S.No.	Tested Parameter *	Result (MPN) **	Protocol Used	Potable / Not Potable
Memo No :- 574, Date :- 20/03/2025				
1	Sample ID:-HSR/13172/3/2025 /Sender : DIG VIJAY MEMORIAL SCHOOL / RO ,Location : , 8KM STONE KAIMRI ROAD HISAR, Analysis Start/End Date: 18/03/2025 / 20/03/2025, GPS Coordinates: 75.722700 /29.085962			
	Total Coliform per 100 ml	0	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023	Potable
2	Sample ID:-HSR/13173/3/2025 /Sender : DIG VIJAY MEMORIAL SCHOOL / WATER SUPPLY ,Location : , 8 KM STONE KAIMRI ROAD, HISAR, Analysis Start/End Date: 18/03/2025 / 20/03/2025, GPS Coordinates: 75.722601 /29.086139			
	Total Coliform per 100 ml	0	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023	Potable
Abstract Report of Bacteriological Examination Report of Water Sample				
Total Sample		Potable	Not Potable	
2		2	0	

* Requirement (Acceptable Limit) : Shall not be detectable in any 100 ml sample

** MPN (Most Probable Number) Per 100 ML.

Remarks :-

- * The Results Given above are related to the sample as received and tested in HISAR lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.

Mandib
Sample analyzed by :

Rajeev
RAJEEV KUMAR, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, HISAR
email:-chemist.hisar@phedharyana.gov.in

Rajesh Vishwak
Principal
Digvijay Memorial School
Kaimri Road, HISAR

Kallu's
Manager
Dig Vijay Memorial School
HISAR